




Member of



Certificate of Conformity with European standards for Components and Systems

Number of Certificate

Valid from
dd-mm-yyyy

Valid until
dd-mm-yyyy

EN-ST-000214

24-09-2015

23-09-2019

Subject matter of Certificate:

**Alarm transmission equipment
GT 00NG, 20NG, 40NG**

Owner of Certificate:

**Chiron Security Communications AG
Baarerstrasse 19
CH-6300 ZUG**

Basis for certification:

**EN 50136-1:2012, EN 50136-2:2013, EN 50131-10:2014
EN 50130-4:2011, EN 50130-5:2011**

Use, the product disposes of the following parameters:

Intrusion and hold-up systems

The tests were carried out at VdS Schadenverhütung GmbH
and the results are documented in **test report:**

140885, 140882, 140889 dated 06-03-2015

VdS Schadenverhütung GmbH
Zertifizierungsstelle
Ansterdamer Str. 174
D-50735 Köln

A company of the German Insurance
Association (GDV) accredited by DAKKS as
certification body for fire protection and
security products

To guarantee the permanent quality of products a regular surveillance of the manufacturing process is performed.

This certificate comprises 4 pages and shall only be reproduced without any modifications and including all enclosures.



Date: 24-09-2015

Managing director

Head of certification body



To Certificate No.: EN-ST-000214

Date : 24-09-2015

The approved component/system comprises the following parts:

Description of component	Type	Applicant's Registration No.	Approval number of component (only complete for system approval)
<p>IRIS GTxxNG SPT for mounting inside Honeywell CIE in the variants described below equipped with the common features:</p> <ul style="list-style-type: none">- Software version V2.7.0- USB connector for local PC configuration- 6 resistance supervised inputs- 4 relay outputs (electronically)- Serial interfaces 1x RS-485 (for Honeywell) <p>Single path (SP5) variant with GPRS transmission path</p> <p>Single path (SP6) variant with Ethernet transmission path</p> <p>Dual path (DP4) variant with GPRS and Ethernet transmission path</p>	<p>GT 00NG</p> <p>GT 20NG</p> <p>GT 40NG</p>		



To Certificate No.: EN-ST-000214

Date : 24-09-2015

The approved component/system is described as follows:

Type of document	Manufacturer's identification	Date	Number of Pages
Installation Manual: - Installation Instructions	Honeywell GT00-NG, GT20-NG & GT40-NG Ethernet and 3G/GPRS Version 1.2	05/2015	10
Drawings			
- Product label GT 00NG	Label-NG-011A, Version 1.1	02.06.2015	1
- Product label GT 20NG	Label-NG-011B, Version 1.1	02.06.2015	1
- Product label GT 40NG	Label-NG-011C, Version 1.1	02.06.2015	1



Enclosure 3

Sheet 1

To Certificate No.: EN-ST-000214

Date : 24-09-2015

Instructions for the application of the approval component/system (see enclosure 1):

The existing Honeywell I-CIE, where the GT xxNG device is mounted, specifies the EN grade of the complete alarm system.